Appendix C

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD SAN DIEGO REGION

SANITARY SEWER OVERFLOW REPORT FORM

AL	ALL ITEMS ARE REQUIRED TO BE ADDRESSED			
1.	This report is (check one)			
2.	Sanitary Sewer Overflow Sequential Tracking Number: 045015			
3.	Reported To: Fax & voicemail - Bryan Ott (Enter Fax, Voice Mail, or Name of Regional Board Staff)			
4.	Date Reported: 02 / 27 / 05 (MM/DD/YY)			
	Time Reported: 15 : 00 (Military or 24 Hour Time)			
5.	Reported By: John Burcham			
6.	Phone: (760)839 -6290			
7.	Reporting Sewer Agency: City of Escondido			
8.	Responsible Sewer Agency: City of Escondido			
9.	Overflow Start: Date: 02 / 27 / 05 (MM/DD/YY)			
	Time Reported: 11:30 (Military or 24 Hour Time)			
	Overflow End: Date: 02 / 27 / 05 (MM/DD/YY)			
	Time Reported: 15:00 (Military or 24 Hour Time)			
10.	Estimated Overflow Flow Rate: 350 Secondary Effluent (Gallons Per Minute)			
11.	Total Overflow Volume: 73,500 Secondary Effluent (Gallons)			
12.	Overflow Volume Recovered: 0 (Gallons)			
13.	Overflow Volume Released To Environment: 73,500 (Gallons)			
Sani	tary Sewer Overflow Location and Description:			
4.	Street and/or Address: City of Escondido Land Outfall Line Manhole #74 (Thomas Bros. pg. 1148 C-4)			
5.	City: Escondido Zip Code: 92029			
6.	County: SD (SD RI OR)			

98%

17	Manhole #74 Thomas Bros. pg. 1148 C-4	
18	Number of overflows within 1,000 feet of this location in past 12 months: 0	
19		
20.		
	Roots Grease Line Break Infiltration	
	Rocks Blockage Power Failure Pump Station Failure	
	Debris Vandalism Flood Damage Manhole Failure	
	Other Unknown Flood Damage Private Property	
21.	- Third Storing of Cause.	
22.	The Hale Avenue Resource Recovery Facility experinced a power failure or fluctuation at 0100 how Feb. 27, 2005. The event was significant enough to start one emergency generator. After power restored a large percentage of the plant equipment had to be reset. The Equalization Pumps were restored a large percentage of the plant equipment had to be reset. The Equalization Pumps were restored a large percentage of the plant equipment had to be reset. The Equalization Pumps were restored a large percentage of the plant equipment had to be reset. The Equalization Pumps were restored to the motor control center and the Program Logic Controller. After the power failure the EQ pumps need to be selected to the Remote Auto position and were not. In turn the pumps did not come when inflict increased. This resulted in the flow to the Escondido Land Outfall to be over capacity, compound the issue a similar power event had caused the loss of the influent flow meter. We used flow meter from the EQ Overflow weir for the influent while a replacement meter is on order. With the meter the excess flow to the outfall was not dectected. OES contacted Control #05-1339 Sanitary Sewer Overflow Correction — Description of all preventative and corrective measures take planned: Staff is working on a high level alarm for the EQ pump wetwell and flow registered on overflow weir notification of operations staff. New/replacement equipment for above mentioned flow meter is on or and will be installed as soon as it arrives. (6 to 8 weeks) An SOP for Power Failure was in the process being written and upon completion will be given to Operations Staff. A tailgate meeting is set for V March 2, 2005 which will cover the Power Failure procedure of checking all Motor Control Centers PLCs. Awareness of equipment required to operate will also be reviewed.	was eet at eded uent To the hout n or for rder es of
23.	Was there measurable precipitation during 72-hour period prior to the overflow? Y or N	
Initi	al and Secondary Receiving Waters:	
24.	Did the sanitary sewer overflow enter a storm drain? Y or N	
25.	Did the sanitary sewer overflow reach surface waters other than a storm drain? Y or N	
26.	Name or description of initial receiving waters. (If none, type none) Drainage area near Lone Jack Rd.	
27.	Name or description of secondary receiving waters. (If none, type none) Escondido Creek/San Elijo Lag	<u>:00</u>

98%

28.	If the sanitary sewer overflow did not reach surface waters, describe the final destination of sewage:
Not	tification:
29.	Was the local health services agency notified? Y X or N
30.	If the overflow was over 1,000 gallons, was the Office of Emergency Services (OES) notified? Y or N or Not Applicable (N/A)
Affe	ected Area Posting:
31.	Were signs posted to warn of contamination? Y or N
32.	Location of posting (if posted): Cardiff State Beach San Elijo Lagoon outlet, 600 ft north and 1/2 mi south
33.	How many days were the warning signs posted? 5
34.	Remarks:
	For items 24 thru 28 the spill was from the Escondido Land Outfall Line which carries Secondar Treated Effluent.
•	
NOT	ES:
1)	For description and clarifications of all items on this form, refer to Order No. 96-04 as amended, including the document entitled, "Required Fields for Order No. 96-04 Quarterly Summary Report."
2)	·
The fo	ollowing certification must be completed with the five (5) day notice:
swez inder locum btain	ir under penalty of perjury that the information submitted in this document is true and correct. I certify penalty of perjury that I have personally examined and am familiar with the information submitted in this nent and all attachment and that, based on my inquiry of those individuals immediately responsible for ing the information, I believe that the information is true, accurate, and complete. I am aware that there enficant penalties for submitting false information, including the possibility of fines and imprisonment.
Jame:	John Burcham
ignat	ure: Jal Beech
itle: <u>H</u>	IARRE Supt.
ote: <u>0.</u>	3/07/05

98%

, · ·